



## PUBLIC NOTICE

### Major Spill

Middle Oconee Wastewater Treatment Plant

2359 Winder HWY

Jefferson GA, 30549

Dates: April 19<sup>th</sup> and 20<sup>th</sup> 2019

1. The Middle Oconee Lift station was flooded by heavy rains April 19th.
2. Approximately 120,000 gallons has been spilled. This is classified as a major spill.
3. JCWSA with assistance from Jackson County Emergency Management and Jackson County Road Department were able to build a berm and pump out the area.
4. The EPD has been notified of the incident.
5. The Health Department has been notified of the incident.
6. EPD requires monitoring upstream and downstream of the spill. Water Quality sampling is required and is expected to last for several days.

If you have any questions, please call **706-367-1741 EXT 302**